



- NOTES:**
1. ALL DIMENSIONS ARE IN MMS, UNLESS OTHERWISE SPECIFIED.
  2. PRINT SCALE: 1/8" = 1'-0", FOLLOW ONLY THE WRITTEN DIMENSIONS.
  3. ALL STRUCTURAL CONCRETE SHALL BE M20 GRADE.
  4. REINFORCEMENT SHALL BE F<sub>415</sub> GRADE.
  5. SPACING OF CLIPS: HORIZONTAL TWICE THE WALL THICKNESS. VERTICAL 15 DIA OF REINFORCEMENT OR 30MM WHICH EVER IS LESS.

KARNATAKA POWER TRANSMISSION CORPN LTD				
DETAILS OF CABLE TRENCH CROSSING ROAD				
FOR 220KV STATIONS				
SHEET 1 OF 2				
DESIGN NO: CBS (P&C) / SE(DVL) / DS-87/220 / 0000				
REVISED NO: 00				
DATE	BY	CHECKED	APPROVED	PLANNING
08/11/88	ANIL	REKHA	CHIEF ENGR	00